



**CAMERON COUNTY PURCHASING**

1100 East Monroe St,  
Brownsville, Texas 78520  
(956) 544-0871 Fax: (956) 550-7219

**ADDENDUM # 3 - PAGE 1 of 2**

**DATE OUT: 7/28/23**

**RFP TITLE: CAMERON COUNTY 835 EAST LEVEE & SAN BENITO ANNEX  
BUILDING STANDBY POWER UPGRADES**

**RFP NUMBER # 230704**

**DEADLINE: August 1, 2023 at 3:00 p.m.**

*(IN ORDER TO AVOID DISQUALIFICATION – ALL ADDENDUMS MUST BE SIGNED AND RETURNED BY DEADLINE AND INCLUDED  
IN THE SEALED BID PACKAGE SUBMITTED)*

**1.- CHANGE # 1**

**Modifications made on July 28, 2023 to the plans/drawings by Ethos Engineering,  
please see page 2.**

**Note:**

*This addendum shall become part of the RFP and all RESPONDERS/PARTICIPANTS shall be bound by its content. All aspects of the scope of work/services not covered herein shall remain the same.*

Company Name \_\_\_\_\_ Phone # \_\_\_\_\_

Vendor Signature \_\_\_\_\_ Date \_\_\_\_\_

***Must include and return with Bid package***



1126 S. Commerce St.  
 Harlingen, TX 78550  
 Off: (956) 230-3435  
 Fax: (956) 720-0830  
[www.ethoseng.net](http://www.ethoseng.net)

July 28, 2023  
 Cameron County 835 East Levee & San Benito Annex Building  
 Standby Power Upgrades



### ADDENDUM NO. 3

#### A. PURPOSE AND INTENT

This addendum is issued for the purpose of modifying the plans for the project referenced above. This addendum shall become part of the contract and all contractors shall be bound by its content. All aspects of the specifications and drawings not covered herein shall remain the same. The General Conditions and the Special Conditions of the specifications shall govern all parts of the work and apply in full force to this addendum.

#### B. DRAWINGS

- 1) Sheet SES1.1:
  - a) Keyed Note #6: Feeder may be routed on building exterior in lieu of indoors. See item #3 below.
- 2) Sheet SE2.2:
  - a) Keyed Note #6: Feeder may be routed on building exterior in lieu of indoors. See item #3 below.
- 3) Sheet SE3.1:
  - a) Keyed Note #9: Feeder between new "ATS" and existing switchboard "MDP" may be routed on building exterior in lieu of indoors due to potential obstructions and conflicts.