



CAMERON COUNTY PURCHASING

1100 East Monroe St,
Brownsville, Texas 78520
(956) 544-0871 Fax: (956) 550-7219

ADDENDUM # 2 - PAGE 1 of 2

DATE OUT: 10/19/23

RFP TITLE: **DARRELL HESTER JUVENILE DETENTION CENTER SMOKE EVACUATION AND HVAC SYSTEMS UPGRADES**

RFP NUMBER # **231001**

DEADLINE: November 15, 2023 at 3:00 p.m.

2nd Pre-Proposal meeting:

Wednesday, October 25, 2023 at 10:30 A.M.

2nd PRE-PROPOSAL MEETING LOCATION:

2310 US- BUS 77, San Benito, Texas 78586

Darrell B. Hester Juvenile Detention Center

CONTACT PERSON: Danny Villarreal, Construction Manager 956-454-1378

(IN ORDER TO AVOID DISQUALIFICATION – ALL ADDENDUMS MUST BE SIGNED AND RETURNED BY DEADLINE AND INCLUDED IN THE SEALED BID PACKAGE SUBMITTED)

1.- Please find response to request for clarifications and/or questions during the first pre-proposal meeting on October 10, 2023. In addition, please find additional language to technical specifications by Engineering Consulting Firm Ethos.

Pease see second page for addendum details:

Note:

This addendum shall become part of the RFP and all RESPONDERS/PARTICIPANTS shall be bound by its content. All aspects of the scope of work/services not covered herein shall remain the same.

Company Name _____ Phone # _____

Vendor Signature _____ Date _____

Must include and return with Bid package

END OF ADDENDUM # 2

10/19/2023



1126 South Commerce
Harlingen, TX 78550
Off: (956) 230-3435
Fax: (956) 720-0830
www.ethoseng.net

October 16, 2023

Darrell Hester Smoke Evacuation and HVAC Systems Upgrades – RFQ #231001

ADDENDUM NO. 2

A. PURPOSE AND INTENT

This addendum is issued for the purpose of modifying the plans for the project referenced above. This addendum shall become part of the contract and all contractors shall be bound by its content. All aspects of the specifications and drawings not covered herein shall remain the same. The General Conditions and the Special Conditions of the specifications shall govern all parts of the work and apply in full force to this addendum.

B. CLARIFICATIONS

1. Estimated Construction Budget: \$2,200,000.00
2. Specification Section 236423 – Scroll Water Chillers:
 - a. Add “Daikin Applied” to the list of acceptable chiller manufacturers. Chillers shall meet or exceed the requirements listed on specifications and drawings.

