



CAMERON COUNTY PURCHASING

1100 East Monroe St,
Brownsville, Texas 78520
(956) 544-0871 Fax: (956) 550-7219

ADDENDUM # 1 - PAGE 1 of 1

DATE OUT: 02/13/2026

BID TITLE: FIRE ALARM SYSTEMS INSPECTIONS

BID NUMBER # 1425 I

DEADLINE: FEBRUARY 19TH, 2026 at 3:00 p.m.

(IN ORDER TO AVOID DISQUALIFICATION – ALL ADDENDUMS MUST BE SIGNED AND RETURNED BY DEADLINE AND INCLUDED IN THE SEALED BID PACKAGE SUBMITTED)

1.- Questions submitted by participants for this BID:

1- Page 22 has the location and type of fire alarm installed, however no count for devices. This would allow me to properly bid it. Please provide me the count, or even the last fire inspection report completed will tell me enough information to provide a proper quote.

ANSWER: Please find Excel sheet as part of this addendum with detail information for each County building and system devices type.

2- On page one, it requests to complete in INK. Is that the only spot for ink? Or can I fill the rest of the information out electronically? Let me know and I can just print and hand write all the information.

ANSWER: Complete bid must be fill out by hand or electronically and submitted in a seal envelope to purchasing department as per instructions in first page. NOTE: First page must be sign in ink.

3-Page 25 says 3 total items, however 4 lines to insert for each system.

ANSWER: This is simply clerical oversight. The 4th location was added this year and the quantity was not updated.

4- Clarification--each bid should include a new battery?

ANSWER: Upon inspection, if a battery for the system needs to be replaced, it will be replaced at that time as needed.

5- Can you provide a record of when the last sensitivity test was performed on the smoke detectors for each site listed on the bid?

ANSWER: The last round of inspections occurred in 2025 between May and July.

6- Can a site visit be scheduled for Superior Alarms representatives to survey the fire alarm systems for each site listed on the bid?

ANSWER: Yes, please call the office at 956-544-0823 to arrange a site visit. On a side note, Superior Alarms was previously the vendor on bid for Fire Alarm Inspections so they should have internal records of all of our sites with the exception of the 2 new additions.

Note:

This addendum is issued for the purpose of answering request for clarifications submitted by participants. This addendum shall become part of the BID and all RESPONDERS/PARTICIPANTS shall be bound by its content. All aspects of the scope of work/services not covered herein shall remain the same.

Company Name _____ Phone # _____

Vendor Signature _____ Date _____

Must include and return with BID package